



Hydrogen Fueling Infrastructure Research and Station Technology

Hydrogen Stations for Urban Sites

PI/Presenter: Brian Ehrhart

Gabriela Bran-Anleu, Ethan Hecht, Chris LaFleur, Alice Muna,
Ethan Sena, Carl Rivkin (NREL), Joe Pratt

Sandia National Laboratories

2018 DOE Hydrogen and Fuel Cells Program Annual Merit Review
and Peer Evaluation Meeting

SAND2018-4097 D

June 13, 2018

Project ID TV148

This presentation does not contain any proprietary, confidential, or otherwise restricted information

Sandia National Laboratories is a multi-mission laboratory managed and operated by National Technology and Engineering Solutions of Sandia, LLC., a wholly owned subsidiary of Honeywell International, Inc., for the U.S. Department of Energy's National Nuclear Security Administration under contract DE-NA0003525.

Timeline

- Task start date: March 2017
- Task end date: September 2018

Budget

- FY17 DOE Funding: \$920k
 - SNL: \$870k
 - NREL: \$50k
- Planned FY18 DOE Funding: \$125k
 - SNL: \$100k
 - NREL: \$25k

Barriers (Delivery)

- A. Lack of Hydrogen/Carrier and Infrastructure Options Analysis
- I. Other Fueling Site/Terminal Operations
- K. Safety, Codes and Standards, Permitting

Partners


- NREL

- H2USA Hydrogen Fueling Station Working group identified station footprint reduction for urban areas as the *#1 priority* for the FY17 H2FIRST projects
- Objective:
 - Create compact gaseous and delivered liquid hydrogen reference station designs appropriate for urban locations, enabled by hazard/harm mitigations, near-term technology improvements, and/or risk-informed (performance-based) layout designs

Barrier from Delivery MYRDD	Impact
A. Lack of Hydrogen/Carrier and Infrastructure Options Analysis	Provide assessment of station footprint possibilities using current technologies and show possibilities for urban siting
I. Other Fueling Site/Terminal Operations	Show how to reduce station footprint within or equivalent to current requirements
K. Safety, Codes and Standards, Permitting	Identify main drivers of station footprint and requirements that do not contribute to reduced risk

- Previous reference station analyses examined system layout, physical footprint, and cost
 - Current effort focuses on reducing station footprint
- Base case designs for delivered gas, delivered liquid, and on-site production via electrolysis
 - Fully compliant, all requirements and setback distances
 - Design calculations use HRSAM ¹
- Comparisons to base cases:
 - New code requirements
 - New delivery methods
 - Gasoline refueling station co-location
 - Underground storage
 - Roof-top storage
 - Performance-based designs
- Compare risk/consequence for specified hazard scenarios
 - Risk and consequence calculations use HyRAM ²


Quantification of absolute risk is difficult; comparisons show trends



¹ <https://hdsam.es.anl.gov/index.php?content=hrsam>


² <http://hyram.sandia.gov/>

- Analyzing larger station sizes
 - Previous studies looked at 100, 200, and 300 kg/day dispensed H₂ with 1 or 2 hoses
 - This work considers only 600 kg/day dispensed H₂ with 4 dispenser hoses on 2 dispensers
- Level of detail increased for station design elements that affect code requirements
 - Flow pressure drop and velocity design rules used to size tubing
 - Setback distances required by NFPA 2 based on both tube pressure and size



Larger and more detailed system description reveals previously unexplored code requirements


Accomplishments: Specified Similar Component Needs for Three Hydrogen Sources



- Compressor
 - 25 kg/hr flow rate (constant 600 kg/day)
 - Outlet pressure of 94.4 MPa (13,688 psi)
 - 75% isentropic efficiency, 91% motor efficiency, and a 110% motor over-design
- Chillers
 - 25.2 kW (7.2 tons) of refrigeration needed for each chiller
 - Aluminum cooling block of 1,330 kg (0.49 m³) needed for each
- Cascade
 - 10 cascade units, each containing 5 (1:1:3) pressure vessels
 - Outlet flow rate 40 kg/hr to each dispenser
 - Low pressure 31.0 MPa (4,500 psi) yields minimum ID of 5.78 mm (0.23")
 - Example tubing 14.3 mm (0.5625"), ID of 6.4 mm (0.25")
- Dispensing
 - 4 fueling positions, 70 MPa, -40°C

• Bulk Gas Storage


- Sized for 33% over daily design capacity
- Max pressure of 50 MPa (7,250 psi)
- 800 kg H₂ yields 25.2 m³ total hydraulic volume
- Multiple cylinders in ISO-sized superstructure
- Connecting tubing 25 kg/hr at minimum pressure 6.9 MPa (1,000 psi) yields minimum ID 9.1 mm
 - Example tubing OD 14.3 mm (0.5625"), ID 9.11 mm (0.359"), pressure rating 103.4 MPa (15,000 psi)



Accomplishments: Minimum Footprint/Full Layouts for Base Case Delivered Gas



- Minimum Footprint
 - Hydrogen station only



- Full Layout
 - Convenience store
 - Parking
 - Traffic flow
 - Delivery





Non-hydrogen station components have large effect on final station layout

Accomplishments: Hazard Scenario Analysis



NFPA 2 Required Scenario	Fueling Station Scenario	Base Case Gas Result
Fire	H ₂ fire resulting from a leak at the H ₂ dispenser	AIR = 2.241×10^{-6} fatalities/year
Pressure Vessel Burst	Compressed gas storage	Mitigations listed for stationary pressure vessels
Deflagration	A H ₂ deflagration within compressor enclosure	3.89×10^5 Pa overpressure for 1% pipe size leak
Detonation	Localized H ₂ /air mixture in vent pipe	Vent pipe L:D ratio is present
Unauthorized Release	Release of H ₂ from storage vessel	Hypoxia met within 4 m of the release point
Exposure Fire	Unrelated vehicle fire at the lot line	Heat flux on dispenser: 4.4 kW/m ²
External Event	Seismic event where largest pipe bursts	AIR = 2.151×10^{-2} fatalities per year, conditional on earthquake
Protection System Out of Service	H ₂ discharge where the interlock fails	No additional risk scenarios because interlocks not credited above
Emergency Exit Blocked	H ₂ system outdoors	Not applicable
Fire Suppression Out of Service	H ₂ system outdoors	Not applicable






Hazard analysis results for base cases will be compared to other cases

Accomplishments: Detailed Design and Hazard Analysis for Delivered Liquid Base Case



- Bulk liquid storage
 - Sized for 33% over daily design capacity
 - 800 kg, 11,299 L (2,985 gal)





- Hazard analysis: two scenarios different than base case gas
 - Hazardous Material Scenario 1 - Release of hydrogen from storage tank
 - Hypoxia and temperature criteria met within 5 m and 10 m of release, respectively
 - Hazardous Material Scenario 3 - Seismic event where a pipe bursts
 - AIR = 8.789×10^{-3} fatalities/year, conditional on earthquake

Hazard analysis results for base case will be compared to other cases

Accomplishments: Detailed Design and Hazard Analysis for On-Site Electrolysis Base Case



- PEM electrolyzer to meet demand
 - H₂ production up to 36 kg/hr
 - Nominal input power ~2MW
 - Tap water consumption <16 liters/kg-H²
 - Approximate footprint 40 ft + 20ft container
- GH₂ low pressure storage (gas reservoir)
 - Total capacity of 25 kg at 50 bar
 - Supplies 15 kg of GH₂ at 20 bar to compressor
- Hazard analysis: only some scenarios different than gas
 - Explosion Scenario 2 – Deflagration
 - Compressor enclosure
 - Electrolyzer enclosure
 - Hazardous Material Scenario 3 - External Event
 - Seismic event where largest pipe bursts
 - Largest pipe is in the electrolyzer container



- Gaseous setback distances
 - Large system can have bulk storage before and after compressor
 - Multiple approaches possible:
 - Single system could take worst-case: maximum pressure from one area and maximum ID from other area
 - Could also calculate setback distances for each system section and select largest

- Liquid setback distances
 - Hybrid system (liquid-to-gas) counted as all-liquid system
 - 800 kg LH2, 620 kg GH2
 - 1,420 kg H2 total, increases setbacks
 - Setback distances are different for most exposures, only a few able to be reduced


	Table 7.3.2.3.1.1	Max. Pressure	Max. ID	Group 1	Group 2	Group 3
Bulk Storage	(a)	50.0 MPa (7,250 psi)	N/A	9 m (29 ft)	4 m (13 ft)	4 m (12 ft)
	(b)		9.07 mm (0.357")	10 m (33 ft)	5 m (16 ft)	4 m (14 ft)
Cascade	(a)	94.4 MPa (13,688 psi)	N/A	10 m (34 ft)	5 m (16 ft)	4 m (14 ft)
	(c)		6.4 mm (0.25")	9 m (30 ft)	4 m (14 ft)	4 m (13 ft)
Single System	(a)	94.4 MPa (13,688 psi)	N/A	10 m (34 ft)	5 m (16 ft)	4 m (14 ft)
	(c)		9.07 mm (0.357")	13 m (43 ft)	7 m (22 ft)	5 m (18 ft)

Group Exposure	Reducible Distance
1 1 Lot lines	* 15 m (50 ft)
1 2 Air intakes	23 m (75 ft)
1 3 Operable openings in buildings	23 m (75 ft)
1 4 Ignition sources	15 m (50 ft)
2 5 Places of public assembly	23 m (75 ft)
2 6 Parked cars	1.7 m (25 ft)
3 7(a)(1) Sprinklered non-combustible building	* 1.5 m (5 ft)
3 7(a)(2)(i) Unsprinklered, without fire-rated wall	* 15 m (50 ft)
3 7(a)(2)(ii) Unsprinklered, with fire-rated wall	* 1.5 m (5 ft)
3 7(b)(1) Sprinklered combustible building	* 15 m (50 ft)
3 7(b)(2) Unsprinklered combustible building	* 23 m (75 ft)
3 8 Flammable gas systems (other than H2)	* 23 m (75 ft)
3 9 Between stationary LH2 containers	1.5 m (5 ft)
3 10 All classes of flammable and combustible liquids	* 23 m (75 ft)
3 11 Hazardous material storage including LO2	* 23 m (75 ft)
3 12 Heavy timber, coal	* 23 m (75 ft)
3 13 Wall openings	15 m (50 ft)
3 14 Inlet to underground sewers	1.5 m (5 ft)
3 15a Utilities overhead: public transit electric wire	15 m (50 ft)
3 15b Utilities overhead: other overhead electric wire	7.5 m (25 ft)
3 15c Utilities overhead: hazardous material piping	4.6 m (15 ft)
3 16 Flammable gas metering and regulating stations	4.6 m (15 ft)

Calculations for larger system may lead to unintended setback distances


- Next edition of NFPA 2 code under review
- Setback distances reduced for bulk gaseous storage
 - For example, for pressure of 94.4 MPa (13,688 psi) and ID of 9.07 mm (0.357")

	Group 1	Group 2	Group 3
Current	13 m (43 ft)	7 m (22 ft)	5 m (18 ft)
Proposed	8 m (25 ft)	6 m (19 ft)	5 m (17 ft)



- Significant impact on minimum footprint, but other factors (traffic and delivery truck path) will likely reduce impact on full layout
- For bulk liquid storage, some setback distance clarifications
 - Fire-rated walls can reduce walls to 0 m, amount of reduction currently unspecified
 - Group 1 and 2 exposures reduced by specific mitigations for delivery unloading connections
 - Likely not a large impact on footprint, but alternate designs with different delivery methods possible

Current NFPA 2 proposals are subject to change, but could have a large impact on station layout




- Delivery truck specifications can have a large impact on station utilization and layout
 - Low delivery capacity or pressure mean station utilization is limited
 - Truck dimensions and turning radius can have a significant impact on station layout
- Delivery truck specifics will depend on local market conditions and supplier availability

	Delivered Gas		Delivered Liquid	
	Base Case	New Delivery	Base Case	New Delivery
Hydrogen Pressure	25 MPa (3626 psi)	50 MPa (7,252 psi)	--	
Hydrogen Capacity	300 kg	1,200 kg	3,000 kg	1,800 kg
Truck-Trailer Length	16.76 m (55 ft)	13.72 m (45 ft)	19.8 m (65 ft)	13.7 m (45 ft)

- Delivered Gas
 - Base assumptions under-utilize station
 - “New” option can fully utilize station
 - Shorter delivery truck will lead to smaller footprint
- Delivered Liquid
 - Both Base Case and “New” can fully supply multiple stations
 - Shorter delivery truck will lead to smaller footprint

Delivery very localized, but can still have major impact on station design

- A code compliant co-location station needs to satisfy the following regulations:
 - NFPA 2 and NFPA55
 - GH₂ is classified as a flammable gas
 - LH₂ is classified as a flammable cryogenic fluid
 - NFPA 30 and 30A
 - Gasoline is classified as a Class IB flammable liquid
- Setback distances for bulk GH₂ and bulk LH₂ systems
 - Group 2 exposures: limits the setback distances to the gasoline dispensers
 - Group 3 (d for GH₂ and 10 for LH₂) exposure: limits the setback distances to the gasoline underground storage tanks (or fill openings).
- Setback distances for Gasoline system (underground storage)
 - Underground storage tanks need to be at least 3 ft from property lines
 - Filling, emptying, and vapor recovery connections should be at least 5 ft from building opening or air intakes



Group 2 - Limit for gasoline dispensers


Group 3 - Limit for gasoline storage tanks

Group 2 and 3 exposures distances can be used to determine layout for co-location station.



- This is a new project, and was not reviewed last year

- H2FIRST itself is a **SNL-NREL** co-led, collaborative project and members of both labs contributed heavily to this project.
- To be as relevant and useful as possible, the project tightly integrated input, learnings, and feedback from many stakeholders, such as:

- H2USA's Hydrogen Fueling Station Working Group 

- California Fuel Cell Partnership

- California Energy Commission

- California Air Resources Board

- UC Berkeley 

- Argonne National Lab 

- H2 Logic 



- Hydrogenics 

- ITM Power 

- Linde 

- Nuvera 

- PDC Machines 

- Proton OnSite 

- Siemens AG 

- First Element 

Remaining barriers and challenges:




- General footprint difficult to apply to nationwide siting study
 - Site-specific considerations difficult to account for
- Code requirements difficult to interpret
 - Could lead to different interpretations by different AHJs
 - More pronounced differences in interpretation for performance-based designs
- Underground and aboveground storage much more site-specific
 - Underground utilities or structures could prevent burial of storage
 - Jurisdiction-specific height restrictions could limit roof-top storage


Future work:



- Underground and roof-top storage analysis
 - Quantify footprint reduction
 - Identify other possible methods for further reduction
- Performance-based designs
 - Smaller than NFPA 2 setbacks, but equivalent or lesser risk
 - Typically site-specific, but can identify general trends
 - Could help inform future code changes
- Economic evaluation
 - Based on previous reference stations
 - Will consider economic impact of different footprint reductions
- National siting study for reduced footprint
 - Can quantify effect of varying footprint size
- Host workshop with stakeholders to present results and outline future needs



Preferred location of stations in San Francisco



Any proposed future work is subject to change based on funding levels

- **Relevance:**
 - Create compact hydrogen reference station designs appropriate for urban locations, enabled by hazard/harm mitigations, near-term technology improvements, and/or risk-informed (performance-based) layout designs
- **Approach:**
 - Direct comparison of hazards/risks for base cases vs. alternative layouts with reduced footprints
- **Accomplishments and Progress:**
 - Completed base case designs and hazard analysis for delivered gas, delivered liquid, and on-site electrolysis
 - Identified upcoming code changes, alternate delivery assumptions, gasoline co-location
- **Future Work:**
 - Underground and roof-top storage analysis
 - Performance-based designs
 - Economic evaluation
 - Siting study for reduced footprint
 - Host workshop



TECHNICAL BACK-UP SLIDES

Compressor, Cascade, and Dispenser P&IDs

